



#8 SCREW ANCHOR CHART			
CALL SIZE	WINDOW SIZE	QUANTITY IN	
		HEAD & SILL	EACH JAMB
		UP TO 70 PSF	UP TO 70 PSF
0606	6 X 6	1	1
0610	6 X 12	1	1
0620	6 X 24	1	2
0630	6 X 36	1	2
0640	6 X 48	1	3
0650	6 X 60	1	3
1006	12 X 6	1	1
1010	12 X 12	1	1
1020	12 X 24	1	2
1030	12 X 36	1	2
1040	12 X 48	1	3
1050	12 X 60	1	3
2006	24 X 6	2	1
2010	24 X 12	2	1
2020	24 X 24	2	2
2030	24 X 36	2	2
2040	24 X 48	2	3
2050	24 X 60	2	3
3006	36 X 6	2	1
3010	36 X 12	2	1
3020	36 X 24	2	2
3030	36 X 36	2	2
3040	36 X 48	2	3
3050	36 X 60	2	3
4006	48 X 6	3	1
4010	48 X 12	3	1
4020	48 X 24	3	2
4030	48 X 36	3	2
4040	48 X 48	3	3
4050	48 X 60	3	3
5006	60 X 6	3	1
5010	60 X 12	3	1
5020	60 X 24	3	2
5030	60 X 36	3	2
5040	60 X 48	3	3
5050	60 X 60	3	3
6006	72 X 6	4	1
6010	72 X 12	4	1
6020	72 X 24	4	2
6030	72 X 36	4	2
6040	72 X 48	4	3
6050	72 X 60	4	3

- NOTES:
- 1) WINDOW FRAME MATERIAL: ALUMINUM ALLOY 6063.
 - 2) #8 INSTALLATION ANCHOR SCREWS MUST BE OF SUFFICIENT LTH. TO ACHIEVE MIN. EMBEDMENT OF 1" INTO WOOD FRAME MEMBER. SPACE #8 SCREW ANCHORS 6" FROM CORNERS & 24" O.C. MAX.
 - 3) CAULK BEHIND WINDOW FIN AT HEAD & JAMBS WITH DUO-SIL ADHESIVE CAULK OR APPROVED EQUAL. APPLICATION OF DUO-SIL ADHESIVE CAULK MUST COMPLY WITH SEALANT MANUFACTURER'S RECOMMENDATIONS. DO NOT CAULK BEHIND SILL FIN.
 - 4) USE LATEX CAULK OR EQUIVALENT FOR PERIMETER SEAL AROUND EXTERIOR OF WINDOW BY OTHERS.
 - 5) IF EXACT WINDOW SIZE IS NOT LISTED IN ANCHOR CHART, USE ANCHOR QUANTITY LISTED WITH NEXT LARGER SIZE, FOR THE APPROPRIATE DESIGN PRESSURE REQ'D.
 - 6) GLASS THICKNESS MAY VARY PER THE REQUIREMENTS OF ASTM E1300 GLASS CHARTS. INSULATING GLASS IS SHOWN, SINGLE GLAZING ALSO QUALIFIED.
 - 7) FACTORY PUNCHED HOLES IN FIN JAMB DO NOT REQUIRE INSTALLATION SCREWS, IF APPLICABLE. INSTALLATION ANCHORS ARE ONLY REQ'D. THRU FIN AS SHOWN ON THIS SHEET.
 - 8) KINCO, LTD'S. TW SERIES WINDOW IS SHOWN. INSTALLATION DETAILS ALSO APPLY TO KINCO'S TB SERIES & MARK 40/50 SERIES PICTURE WINDOWS.

KINCO, LTD. JACKSONVILLE, FLORIDA			
TITLE: FIN PICTURE WINDOW INSTALLATION DRAWING			
ENGINEER: MANUEL MARTINEZ	DRN: BB	DATE: 12/19/01	
DISCIPLINE: CIVIL	SCALE: N.T.S.	DWG. NO: KJAX0082	
FL. REG. NO: 47182	REV. LETTER:	SHEET: 1 OF 1	