

HURRICANE MITIGATION RETROFITS FOR EXISTING SITE-BUILT SINGLE FAMILY RESIDENTIAL STRUCTURES

201.1 Roof sheathing fastening for site-built single-family residential structures. For site-built single family residential structures the fasteners and spacing required in Table 201.1 are deemed to comply with the requirements of Section 507.2.2 544.5, of the 2004 Florida Building Code, Existing Building.

Board roof decking secured with at least two 8d nails into roof framing members shall be deemed to be sufficiently connected. Board roof decking secured with smaller fasteners than 8d nails or with fewer than two 8d nails per board shall be deemed sufficiently connected if two 8d clipped head, round head, or ring shank nails are in place on each framing member.

Supplemental fasteners as required by Table 201.1 shall be 8d ring shank nails with round heads and the following minimum dimensions:

1. 0.113 inch nominal shank diameter
2. Ring diameter of 0.012 over shank diameter
3. 16 to 20 rings per inch
4. 0.280 inch full round head diameter
5. 2-1/4 inch nail length

**Table 201.1
Supplemental Fasteners at Panel Edges and Intermediate Framing**

Existing fasteners	Existing spacing	Wind speed 110 mph or less supplemental fastening shall be no greater than	Wind speed greater than 110 mph supplemental fastening shall be no greater than
Staples or 6d	Any	6" o.c. ^b	6" o.c. ^b
8d clipped head, round head, or ring shank	6" o.c. or less	None necessary	None necessary
8d clipped head or round head	Greater than 6" o.c.	6" o.c. ^a	6" o.c. ^b
8d round head ring shank	Greater than 6" o.c.	6" o.c. ^a	6" o.c. ^a

- a. Maximum spacing determined based on existing fasteners and supplemental fasteners.
- b. Maximum spacing determined based on supplemental fasteners only.

201.2 Roof secondary water barrier for site-built single-family residential structures. A secondary water barrier shall be installed using one of the following methods when roofing replacement when re-roofing.

- a) All joints in roof sheathing or decking shall be covered with a minimum 4 in. wide strip of self-adhering polymer modified bitumen tape applied directly to the sheathing or decking. The deck and self-adhering polymer modified bitumen tape shall be covered with one of the underlayment systems approved for the particular roof covering to be applied to the roof.
- b) The entire roof deck shall be covered with an approved self-adhering polymer modified bitumen cap sheet. No additional underlayment shall be required on top of this cap sheet for new installations.

EXCEPTIONS:

1. An asphalt impregnated 30# felt underlayment installed with nails and tin-tabs as required for the HVHZ and covered with either an approved self-adhering polymer modified bitumen cap sheet or an approved cap sheet applied using an approved hot-mop application shall be deemed to meet the requirements for the secondary water barrier.