



ELEVATION  
VIEWED FROM EXTERIOR

- NOTES:
- 1) SHIM AS REQ'D. AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM. MAX. ALLOWABLE SHIM STACK TO BE 1/4".
  - 2) WINDOW FRAME MATERIAL: ALUMINUM ALLOY 6063.
  - 3) INSTALLATION ANCHORS MUST BE OF SUFFICIENT LENGTH TO ACHIEVE MIN. EMBEDMENT OF 1" INTO WOOD FRAME.
  - 4) USE SILICONIZED ACRYLIC CAULK FOR PERIMETER SEAL AROUND EXTERIOR OF WINDOW FRAME.
  - 5) USE SILICONIZED ACRYLIC CAULK BEHIND WINDOW FIN.
  - 6) GLASS THICKNESS MAY VARY PER REQUIREMENTS OF ASTM E1300 GLASS CHARTS. SINGLE GLAZING IS SHOWN, INSULATING GLASS ALSO QUALIFIED.
  - 7) FLORIDA EXTRUDERS 2000 SERIES FIXED PICTURE WINDOW IS SHOWN. THIS PRINT ALSO APPLIES TO THE FLORIDA EXTRUDERS 1500 AND 1000 SERIES PICTURE WINDOW.
  - 8) SPACE INSTALLATION ANCHORS AT 6" MAX. FROM CORNERS AND MAX. 24" O.C. DESIGN PRESSURE CAPACITY OF INSTALLATIONS, WITH ANCHOR SPACING AS STATED, IS 70.0 PSF FOR ALL AVAILABLE SIZES UP TO 73" X 71" OR 63" X 95" OR 119" X 37-3/8" MAX.
  - 9) WINDOW UNIT CAN BE MULLIONED TO OTHER UNITS USING ALUMINUM TUBE MULLION. SEE MULLION INSTALLATION SHEETS FOR REQUIREMENTS.

*[Handwritten Signature]*  
FEB 21 2002

FLORIDA EXTRUDERS INTERNATIONAL, INC SANFORD, FLORIDA	
TITLE: INSTALLATION DETAIL W/ #8 WOOD SCREW FIXED FIN WINDOW - SERIES 2000	
DRAWN BY: BB	APPROVED BY:
DATE: 1/13/02	SCALE: N. T. S. DWG.: FLEX0030