



INSTALLATION ANCHOR CHART			
CALL SIZE	WINDOW SIZE	QUANTITY IN	
		HEAD & SILL	EA. JAMB
		UP TO 70psf	UP TO 70psf
2020 XO, OX	24 X 24	2	2
2030 XO, OX	24 X 36	2	2
2040 XO, OX	24 X 48	2	3
2050 XO, OX	24 X 60	2	4
3020 XO, OX	36 X 24	2	2
3030 XO, OX	36 X 36	2	2
3040 XO, OX	36 X 48	2	3
3050 XO, OX	36 X 60	2	4
4020 XO, OX	48 X 24	3	2
4030 XO, OX	48 X 36	3	2
4040 XO, OX	48 X 48	3	3
4050 XO, OX	48 X 60	3	4
5020 XO, OX	60 X 24	4	2
5030 XO, OX	60 X 36	4	2
5040 XO, OX	60 X 48	4	3
5050 XO, OX	60 X 60	4	4
6020 XO, OX	72 X 24	4	2
6030 XO, OX	72 X 36	4	2
6040 XO, OX	72 X 48	4	3
6050 XO, OX	72 X 60	4	4
6020-C XO	72 X 24	4	2
6030-C XO	72 X 36	4	2
6040-C XO	72 X 48	4	4
6050-C XO	72 X 60	4	4
7020-C XO	84 X 24	5	2
7030-C XO	84 X 36	5	2
7040-C XO	84 X 48	5	4
7050-C XO	84 X 60	5	4
8020-C XO	96 X 24	5	2
8030-C XO	96 X 36	5	2
8040-C XO	96 X 48	5	4
8050-C XO	96 X 60	5	4
9020-C XO	108 X 24	6	2
9030-C XO	108 X 36	6	2
9040-C XO	108 X 48	6	4
9050-C XO	108 X 60	6	4

NOTES:

- 1) WINDOW FRAME MATERIAL: ALUMINUM ALLOY 6063.
- 2) #8 INSTALLATION ANCHOR SCREWS MUST BE OF SUFFICIENT LTH. TO ACHIEVE MIN. EMBEDMENT OF 1" INTO WOOD FRAME MEMBER.
- 3) CAULK BEHIND WINDOW FIN @ JAMBS & HEAD WITH DUO-SIL ADHESIVE CAULK OR APPROVED EQUAL. APPLICATION OF DUO-SILL ADHESIVE CAULK SEALANT MUST COMPLY WITH SEALANT MANUFACTURER'S RECOMMENDATIONS. DO NOT CAULK BEHIND SILL FIN.
- 4) USE LATEX CAULK OR EQUIVALENT FOR PERIMETER SEAL AROUND EXTERIOR OF WINDOW FLANGE BY OTHERS.
- 5) IF EXACT WINDOW SIZE IS NOT LISTED IN ANCHOR CHART, USE ANCHOR QUANTITY LISTED WITH NEXT LARGER SIZE, FOR THE APPROPRIATE DESIGN PRESSURE REQ'D.
- 6) GLASS THICKNESS MAY VARY PER THE REQUIREMENTS OF ASTM E1300 GLASS CHARTS. SINGLE GLAZING IS SHOWN, INSULATING GLASS ALSO QUALIFIED.
- 7) FACTORY PUNCHED HOLES IN FIN JAMB DO NOT REQUIRE INSTALLATION SCREWS. IF APPLICABLE, INSTALLATION ANCHORS ARE ONLY REQ'D. THRU FIN AS SHOWN ON THIS SHEET.
- 8) KINCO, LTD'S. RW-4 SERIES WINDOW IS SHOWN. INSTALLATION DETAILS ALSO APPLY TO KINCO'S RW-5 SERIES WINDOWS.

KINCO, LTD.
JACKSONVILLE, FLORIDA

TITLE: SERIES RW-4 HOR. ROLLER FIN WOOD FRAME OPENING OX / XO & XO		
ENGINEER: MANUEL MARTINEZ	DRN: BB	DATE: 12/06/01
DISCIPLINE: CIVIL	SCALE: N.T.S.	DWG. NO: KJAX-0079
FL. REG NO: 47182	REV. LETTER:	SHEET: 1 OF 1