



**Orange County Utilities Water Division
BACKFLOW PREVENTER FIELD TEST REPORT**

PLEASE PRINT or TYPE

Customer Name: _____
 Service Address: _____ City: _____ State: _____ Zip: _____
 Account #: _____ Meter #: _____ Reading: _____
 (required)

Company Name/Contractor: _____
 Mailing Address: _____ City: _____ State: _____ Zip: _____
 Phone: _____ Fax: _____ Email: _____
 Gauge Mfr.: _____ Serial #: _____ Calibration Date: _____

Check Areas

Point of Use: Irrigation Fire Domestic Reclaimed Service
Assembly: Reduced Pressure Double Check Pressure Vacuum Breaker
Device: Existing New

Mfr.: _____ Model #: _____ Size: _____ Serial #: _____
 Device Location: _____

ASSEMBLY TEST

	Check Valve (CV) #1	CV # 2	Relief Valve	PVB	Shutoff Valves (SV)
Assembly Test	Closed Tight	Closed Tight	Opened at _____	Air Inlet Opened at _____ PSID	SV # 1 Closure
Annual	Leaked	Leaked	_____ PSID	Did Not Open	Leaked
Retest	PSID Across Check Valve _____	PSID Across Check Valve _____	Did Not Open	PSID CV Closed at _____	SV # 2 Closure
			Exercised	Leaked	Leaked
Repairs	Cleaned	Cleaned	Cleaned	Cleaned	Cleaned
	Replaced	Replaced	Replaced	Replaced	Replaced
	Repaired	Repaired	Repaired	Repaired	Repaired

This operational test Passed _____ or Failed _____. I certify this test to be a true operational representation of the above assembly at the time and date of this test. Date: _____ Time: _____

Comments:

Tester's Name (print): _____ Tester's Signature: _____

Certification #: _____ Issue Date: _____ OCU Tester Registration #: _____

Test Report must be maintained for a period of 10 years per DEP-62-550.720(3)

Provide Test Report To: Owner of the assembly and
 Orange County Utilities Water Division, c/o Cross Connection Control Program
 8100 Presidents Drive, Suite C, Orlando, Florida 32809
 Phone: 407-836-6970, Fax: 407-836-6830, Email: Water.Backflow@ocfl.net

Para más información, por favor llame al Departamento de Servicios Públicos del Condado de Orange y pida hablar con un representante en español. El número de teléfono es 407-836-6970.